

Your Apartment Home is Equipped With a Battery Operated Carbon Monoxide (CO) Alarm. Please take a few Minutes to Read through this Users Guide and become familiar with the Operation, testing and use of the (CO) Alarm.

What To Do When

The Alarm Sounds

1. Operate the Test / Reset Button
2. Call Emergency Services @ 911
3. Move outside into fresh air at once, or near an open window. Check to see that all occupants of your residence are accounted for.

Do not return to your apartment or away from the open window until:

- a. Emergency Service Responders have arrived,
- b. The apartment has been aired out,
- c. Your CO Alarm remains in a normal condition.

WARNING:
Actuation of your CO Alarm Indicates the presence of Carbon Monoxide (CO) Which could result in serious illness and death.

After Following Steps 1 Through 3, Call the Harbor Club Office at **302 731-7948** for Service. One of our Staff Technicians will inspect your Heating unit for proper operation and Investigate any other possible sources of CO which may have caused the Alarm to Activate.

LIGHTS:

RED ALARM LIGHT

4 Quick Flashes
with Alarm Tones —
Followed by 5 seconds OFF —

Followed by 4 Quick Flashes with Alarm (repeating pattern) indicates the presence of Carbon Monoxide. Follow Steps 1, 2, & 3.

When the **Red light** flashes once every 30 seconds along with a “chirp” tone, the batteries need to be replaced. Call 302 731-7948 for Maintenance service

GREEN - OPERATE LIGHT

The **Green Light** indicates the unit is working properly It will flash every 30 seconds indicating that a CO reading is being taken

NOTE: The following substances can effect the sensor and may cause false readings: Methane, **propane (lighter fuel)**, iso-butane, iso-propanol, ethylene, benzene, toluene, ethyl acetate, hydrogen, sulfide, sulfur dioxides, **alcohol based products, paints, thinners, solvents, adhesives, hair spray, after shave, perfumes, and some cleaning agents.**